

DETAILS OF NETHOUSE
(To be submitted with IPA Application)

Name of Beneficiary : _____

Address : _____

SR. NO	PARTICULARS	SPECIFICATION OF NHB	PROPOSED SPECIFICATION	REMARK
1.	Type of structure	Nethouse		
2.	Area in sq.mt	_____ SQM.		
3.	Height of structure	4.0 meter		
4.	Foundation pipe	1.20 mtr. length 2 mm thick		
5.	Column	60 mm OD, 2mm thick, weight 2.85kg/mtr		
6.	Purlin	42 mm OD 2 mm thick weight 2.0/2.10 kg per mtr.		
7.	Balcony pipe	48 mm OD 2 mm thick 2.3 kg/mtr.		
8.	Top Net (shade net/ Insect net)	UV stabilized 30% to 75% shade of any colour		
9.	Nut bolts	Size 3/8"		
10.	Civil work/Foundation	40 cm x 90 cm length		
11.	Corner/Four way/ Five way/ Angle –L	48 mm OD 2mm thick length 0.15 mtr		
12.	Extra items, if any a) Sliding Net b) Trellis system c)			

(Signature of Applicant)

DETAILS OF POLY HOUSE

(To be submitted with IPA Application)

Name of Beneficiary : _____

Address : _____

NATURALLY VENTILATED POLYHOUSE (NVPH)

SR. NO	PARTICULARS	SPECIFICATION OF NHB	PROPOSED SPECIFICATION	REMARK
1.	Type of structure	NVPH		
2.	Area in sq.mtrs.			
3.	Gutter Height	4.0 to 4.5 mtrs		
4.	Ridge Height/Centre height	6.0 to 6.5 mtrs		
5.	Foundation pipe	60 mm OD 1200 to 1300 mm length 3 mm thick weight 4.20 kgs/mtrs.		
6.	Column	76 mm OD, 2mm thick, weight 3.75 kg/mtrs.		
7.	Top Purlin	48 mm OD/2.0 mm thick, weight 2.30 kg/mtrs.		
8.	Gutter Purlin	42 mm OD 2mm thick, weight 2.10k g/mtrs.		
9.	Top Arch	42 mm OD 2mm thick, weight 2.10kg/mtrs.		
10.	Bottom cord of the Truss	60 mm OD/2.0 mm thick, weight 2.85kg/mtrs.		
11.	Internal Bracing pipe & Cross Bracing	33 mm OD 2mm thick, weight 1.60kg/mtrs.		
12.	Balcony pipe	60 mm OD 2mm thick, 2.85kg/mtrs.		
13.	Curtain runner	42 mm OD 2mm thick, weight 2.10kg/mtrs.		
14.	Curtain shaft	27 mm OD 2mm thick, weight 1.30 kg/mtrs.		

15.	Hockey support	33 mm OD 2mm thick, weight 1.60 kg/mtrs.		
16.	Flap control pipe	21 mm OD 2mm thick, weight 1.08 kg/mtrs.		
17.	Poly film	UV stabilized 200 micron		
18.	Fastners	M6 to M10 Nut bolts 50- 150 mm long		
19.	Shade net	UV stabilized 50% shade net of any colour with manual or auto operation		
20.	Bottom Apron	0.6 to 1.5 meter height		
21.	Nut bolts	Size 3/8''		
22.	Civil work/Foundation	45 cm dia. and 75cm to 90 cm depth		
23.	Extra items if any a) Down take pipe b) Trellis system c)			

(Signature of Applicant)